### General Large-Scale Carbon Dioxide Enhanced Oil Recovery Facility Design for the Illinois Basin

Ray W. McKaskle,<sup>1</sup> Carrie M. Beitler,<sup>1</sup> Austyn E. Vance,<sup>1</sup> and Scott M. Frailey<sup>2</sup>

<sup>1</sup>Trimeric Corporation, Buda, Texas

<sup>2</sup>Illinois State Geological Survey, Prairie Research Institute, University of Illinois at Urbana-Champaign, Champaign, Illinois



Circular 592 2017

**ILLINOIS STATE GEOLOGICAL SURVEY** Prairie Research Institute University of Illinois at Urbana-Champaign

**ILLINOIS** Illinois State Geological Survey PRAIRIE RESEARCH INSTITUTE **Front cover:** *Typical vertical vessel high-pressure suction scrubber and compressor. Typical low-pressure suction scrubbers and compressors are similar in appearance. Photograph courtesy of Denbury Onshore.* 

 $\hfillinois$  Board of Trustees. All rights reserved. For permissions information, contact the Illinois State Geological Survey.

### General Large-Scale Carbon Dioxide Enhanced Oil Recovery Facility Design for the Illinois Basin

Ray W. McKaskle,<sup>1</sup> Carrie M. Beitler,<sup>1</sup> Austyn E. Vance,<sup>1</sup> and Scott M. Frailey<sup>2</sup>

<sup>1</sup>Trimeric Corporation, Buda, Texas

<sup>2</sup>Illinois State Geological Survey, Prairie Research Institute, University of Illinois at Urbana-Champaign, Champaign, Illinois

Circular 592 2017

### ILLINOIS STATE GEOLOGICAL SURVEY

Prairie Research Institute University of Illinois at Urbana-Champaign 615 E. Peabody Drive Champaign, Illinois 61820-6918 http://www.isgs.illinois.edu



### DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

### **Technical Report**

Principal Investigator: Sallie Greenberg Illinois State Geological Survey Prairie Research Institute University of Illinois (217) 244-4068 sallieg@illinois.edu Report Issued: May 31, 2016

### U.S. DOE Cooperative Agreement: DE-FC26-05NT42588

The Board of Trustees of the University of Illinois Linda Gregory, Director c/o Grants & Contracts Office 1901 S. First Street Suite A, MC-685 Champaign, IL 61820 Illinois State Geological Survey

> Report prepared by team member: Trimeric Corporation

Suggested citation:

McKaskle, R.W., C.M. Beitler, A.E. Vance, and S.M. Frailey, 2017, General large-scale carbon dioxide enhanced oil recovery facility design for the Illinois Basin: Champaign, Illinois State Geological Survey, Circular 592, 30 p.

### Contents

| Executive Summary  | 1   |
|--|---|
| Introduction   | 3   |
| <b>Enhanced Oil Recovery Surface Facility Design Basis</b><br>Scope of Work<br>Description of Cases<br>Oil and Water Production Rate Assumptions<br>Process Configurations   | 3<br>3<br>3<br>5<br>5   |
| Equipment Design and Cost Analysis Summary         Equipment Sizing         Separators         Chemical Injection System         Oil Storage Tank         Water Storage Tank         Air Coolers         CO2 Compressor Trains         Dehydration         Buildings         Capital Costs         Differences in Small- and Large-Scale Enhanced Oil Recovery Studies         Oil and Water Production Ratios         CO2 Compressor Trains         Water Storage Tanks         Natural Gas Liquid Recovery         Demulsifer Chemicals         Dehydration         Goperating Cost Information         Fixed Capital Investment         The General Fixed Capital Investment Cost Relationship         Fixed Capital Investment Model Development         Effect of Facility Inlet Pressure | $\begin{array}{c} 6\\ 6\\ 8\\ 8\\ 8\\ 8\\ 8\\ 8\\ 9\\ 10\\ 10\\ 10\\ 10\\ 10\\ 10\\ 10\\ 10\\ 10\\ 11\\ 11$ |
| Miscellaneous Cost Items<br>Environmental Controls<br>Flowline Piping  | 13<br>13<br>16  |
| Conclusions  | 16  |
| Acknowledgments  | 17  |
| References   | 17  |
| Appendix A: Process Flow Diagrams for Cases 1–6  | 19  |
| Annendix B. Fauinment List and Durchased and Installed Costs   | 10  |
| for Cases 1-6  | 25  |

### **Tables**

| 1                     | Case summary for the large-scale enhanced oil recovery surface facility study        | 4  |
|-----------------------|--|----|
| 2                     | Assumed peak characteristics of the produced gas                                     | 5  |
| 3                     | Total purchased and installed costs  | 10 |
| 4                     | Operating cost summary   | 12 |
| 5                     | Summary of the total fixed capital investment  | 14 |
| 6                     | Effect of facility inlet pressure on the high-pressure compressor purchased cost     | 15 |
| 7                     | Low-pressure compressor purchased equipment cost estimates                           | 16 |
| 8                     | Unit purchased material capital costs for flowline piping                            | 17 |
| B1                    | Case 1—Major equipment list, and purchased and installed costs                       | 25 |
| B2                    | Case 2—Major equipment list, and purchased and installed costs                       | 26 |
| B3                    | Case 3—Major equipment list, and purchased and installed costs                       | 27 |
| B4                    | Case 4—Major equipment list, and purchased and installed costs                       | 28 |
| B5                    | Case 5—Major equipment list, and purchased and installed costs                       | 29 |
| B6                    | Case 6—Major equipment list, and purchased and installed costs                       | 30 |
| <b>T</b> <sup>•</sup> |  |    |
| Figur                 | es   |    |
| 1                     | Typical horizontal free water knockout vessel  | 7  |
| 2                     | Typical vertical vessel high-pressure suction scrubber and compressor                | 7  |
| 3                     | Fixed capital investment as a function of the $CO_2$ recycle rate and inlet pressure | 14 |
| 4                     | Fixed capital investment model comparison with estimated costs                       | 15 |

4Fixed capital investment model comparison with estimated costs15A1Process flow diagram for Case 119A2Process flow diagram for Case 220A3Process flow diagram for Case 321A4Process flow diagram for Case 422A5Process flow diagram for Case 523A6Process flow diagram for Case 624

### **EXECUTIVE SUMMARY**

The Midwest Geological Sequestration Consortium (MGSC) is leading a program to demonstrate the feasibility of carbon dioxide (CO<sub>a</sub>) capture and storage, particularly in the Illinois Basin (ILB). One potential storage method uses CO<sub>2</sub> for enhanced oil recovery (EOR) by injecting it into producing oil reservoirs whose production rates have been diminished by conventional means (e.g., waterflooding). A fraction of the CO<sub>2</sub> that is injected returns to the surface with the produced oil and is captured and compressed for reinjection. Trimeric, working with the MGSC, has developed conceptual process designs and estimated the costs for a variety of EOR surface processing facility configurations so that the CO<sub>2</sub> accompanying the produced oil can be captured and reinjected. The scope of the facility work included the following major tasks:

- Determining the equipment that would be required for typical facilities;
- Identifying capacity breakpoints in the major equipment (i.e., compressor frame sizes);
- Estimating capital and operating costs for the facilities; and
- Evaluating the feasibility and applicability of natural gas liquid (NGL) recovery from the recycled CO<sub>2</sub>.

The conceptual facility designs included the equipment required to separate

produced liquids from the CO<sub>a</sub>, storage and disposal of the produced liquids, and compression of the CO<sub>2</sub> to be reinjected. The current evaluation included CO<sub>2</sub> recycle rates ranging from 59,000 to 236,000 Sm<sup>3</sup>/h (standard cubic meters per hour; 50 to 200 MMscfd [million standard cubic feet per day]) with facility inlet pressures of 1,034 and 2,172 kPag (kilopascal gauge; 150 and 315 psig [pounds per square inch gauge]) and a facility discharge pressure of 6,895 kPag (1,000 psig). An initial study performed in 2013 similarly evaluated EOR surface facilities with CO<sub>2</sub> flow rates ranging from 1,180 to 24,780  $\text{Sm}^3/\text{h}$  (1 to 21 MMscfd) with the same facility inlet pressures of 1,034 and 2,172 kPag (150 and 315 psig) and with discharge pressures of 3,448 and 6,895 kPag (500 and 1,000 psig).

The feasibility of NGL recovery of propane and heavier  $(C_{3+})$  components was also assessed in the 2013 evaluation for the smaller facilities. The 2013 evaluation concluded that the lean produced gas anticipated in the ILB would likely require costly cryogenic processing to achieve significant NGL recovery, and thus would be uneconomical. If the recycled CO<sub>a</sub> from actual operating EOR facilities in the ILB is eventually found to be richer in NGL components than originally expected, the economic feasibility of NGL recovery can be reevaluated. Lower crude oil prices observed in 2015 and early 2016 would also impede the implementation of NGL recovery.

The purchased equipment costs for the small-scale EOR facilities without NGL recovery were estimated to range from approximately \$1 million for the case with a 1,200 Sm3/h (1 MMscfd) CO2 rate and 3,448 kPag (500 psig) discharge pressure up to approximately \$5.5 million for the case with a 24,800 Sm3/h (21 MMscfd) CO<sub>2</sub> rate and 6,895 kPag (1,000 psig) discharge pressure. The estimated total fixed capital investment (FCI) for facilities that require all new infrastructure ranged from approximately \$3 million to \$16.4 million, excluding NGL recovery. The FCI is the total cost for a new facility that requires the installation of basic facility infrastructure in addition to the EOR equipment.

After the 2013 evaluation was completed, the MGSC requested that additional cases be evaluated for larger scale EOR applications without NGL recovery. In this study, EOR surface facility cases were evaluated with CO<sub>2</sub> recycle rates ranging from 59,000 to 236,000 Sm<sup>3</sup>/h (50 to 200 MMscfd) at the same two facility inlet pressures as the smaller cases, but with only one discharge pressure of 6,395 kPag (1,000 psig). The estimated purchased equipment costs for the large-scale EOR facilities ranged from \$6.7 million for the case with a 59,000 Sm<sup>3</sup>/h (50 MMscfd) CO<sub>a</sub> rate and 2,172 kPag (315 psig) inlet pressure up to \$27.2 million for the case with a 236,000 Sm<sup>3</sup>/h (200 MMscfd) CO<sub>2</sub> rate and an inlet pressure of 1,034 kPag (150 psig). The estimated FCIs were approximately \$20 million and \$81.6 million for the same cases, respectively.

### **INTRODUCTION**

The Midwest Geological Sequestration Consortium (MGSC), working as one of the Regional Carbon Sequestration Partnerships for the U.S. Department of Energy, has conducted a three-phase program to demonstrate the feasibility of carbon dioxide (CO<sub>2</sub>) capture and storage. One of the storage options involves injecting the CO<sub>2</sub> in mature oil fields for enhanced oil recovery (EOR). In this report, the design and costs are evaluated for *large-scale* surface facility processing equipment for EOR applied to mature oil fields with characteristics similar to those in the Illinois Basin (ILB), as part of the MGSC's Development Phase (Phase III). The large-scale EOR CO<sub>2</sub> recycle rates considered in this work ranged from 59,000 to 236,000 Sm3/h (standard cubic meters per hour; 50 to 200 MMscfd [million standard cubic feet per day]).

Previous work performed in 2013 evaluated smaller scale EOR facilities with CO<sub>2</sub> recycle rates from 1,200 to 24,800 Sm3/h (1 to 21 MMscfd). In the 2013 evaluation, the natural gas liquid (NGL) recovery for propane and heavier  $(C_{3+})$  compounds was also assessed, but was found to be uneconomical because the produced gas from the ILB is expected to be rather lean (0.03 L/m<sup>3</sup> or 0.22 GPM [gallons of recoverable hydrocarbon NGL per thousand standard cubic feet of gas; see Myers et al. 2017, A Universal Methodology to Devolop, Test, and Calibrate a Carbon Dioxide Enhanced Oil Recovery and Storage Capacity Estimate]). More expensive NGL recovery processes, such as cryogenic technologies, would likely be required to recover substantial amounts of NGL from the lean gas, and the costs of such technologies would be prohibitive. Recycled CO<sub>2</sub> gas containing at least 0.66 to 0.92 L/ m<sup>3</sup> (5 to 7 GPM) would likely be required to make the economics of NGL recovery potentially feasible. Details of the smallscale EOR evaluation and NGL study can be found in the final version of that report (Trimeric Corporation 2016).

The objective of this report is to provide information and calculation tools that could be used to help determine the feasibility of implementing *large-scale* CO<sub>2</sub> EOR in the ILB. This evaluation considers the surface process equipment required to compress and dehydrate CO<sub>2</sub> and to

separate produced oil, water, and CO<sub>2</sub>. The costs of the CO<sub>2</sub> delivery pipeline, injection wells, and production wells are not included in this evaluation, with the exception of unit costs for piping materials that could be used for flowlines to bring produced fluids to the central facility and to deliver CO<sub>2</sub> from the central facility to the injection wells. Field-wide costs are also not covered in this report. The process configurations and costs provided in this report are intended as examples that are representative of typical large-scale EOR surface facilities, but alternative configurations may be equally feasible or preferable.

### ENHANCED OIL RECOVERY SURFACE FACILITY DESIGN BASIS

This section describes the scope of work and assumptions for the surface facility cases evaluated. The cases were intended to bracket the expected range of field and equipment capacities and conditions that could be typical for large-scale  $CO_2 EOR$ in the ILB.

### **Scope of Work**

The scope of work for the EOR surface facility evaluation was developed jointly by the Illinois State Geological Survey (ISGS) and Trimeric. The following list summarizes the scope of work by Trimeric, which is the subject of this report:

- Develop process requirements and configurations, and prepare process flow diagrams for typical large-scale EOR surface facilities.
- Determine what equipment is needed, and then size the equipment.
- Define why the equipment is required and discuss other conditions in which some of the equipment may be unnecessary. Develop a "minimum requirement" equipment case.
- Determine the minimum-size facility for this large-scale evaluation.
- Determine the maximum-size facility (to address the feasibility of a large facility at a single, large oil field and the possibility of a central gas-handling facility for surrounding smaller fields).

- Prepare purchased equipment cost estimates for equipment defined per the previous items.
- Prepare installed equipment cost estimates.
- Estimate the fixed capital investment (FCI) for these surface processing facilities.
- Provide information needed for any further economic analysis related to the surface processing facilities, including the following:
  - Unit operating costs
    - Electricity (kWh)
    - Include an on-stream factor (percentage of time the facility is running)
    - Include a capacity factor (average percentage of the full production capacity during operations)
    - Cost of chemical treatments (emulsion breakers)
    - Number of operators and labor costs
    - Maintenance costs (spare parts)
    - Consumable costs (compressor lubrication oil, filters)
  - o Annual operating costs

The NGL recovery was not evaluated for large-scale EOR facilities in this report because during the 2013 EOR surface facility evaluation, it was found to be impractical for the lean produced gas expected from ILB oil fields, even at the higher  $CO_2$  recycle rates considered for the large-scale EOR facilities.

### **Description of Cases**

A list of cases was developed to cover the range of conditions (i.e., gas, oil, and water production rates, facility inlet pressure, and facility outlet pressure) anticipated for large-scale EOR facilities in the ILB. Table 1 shows the six cases selected for this evaluation. The 1,034 and 2,172 kPag (kilopascal gauge; 150 and 315 psig [pounds per square inch gauge]) facility inlet pressures were selected to show the impact of suction pressure on the compression costs required to achieve the same 6,895 kPag (1,000 psig) discharge pressure. The ISGS provided the facility outlet (injection) pressure of 6,895 kPag (1,000 psig) based on the anticipated miscible CO<sub>2</sub> flood surface and bottomhole pressure requirements. The temperature

|            | Peak gas                           |  | Peak water                       | Peak oil                         | Facility inlet           | Facility outlet          | High-pressure   |
|------------|------------------------------------|--|----------------------------------|----------------------------------|--------------------------|--------------------------|---|
| Case       | production rate,<br>Sm³/h (MMscfd) | Peak gas production rate,<br>m³/min (acfm) | production rate,<br>m³/d (bbl/d) | production rate,<br>m³/d (bbl/d) | pressure, kPag<br>(psig) | pressure, kPag<br>(psig) | compressor installation phases, Sm <sup>3</sup> /h (MMscfd) |
| -          | 59,000 (50)                        | 89 (3,140)                                 | 1,908 (12,000)                   | 477 (3,000)                      | 1,034 (150)              | 6,895 (1,000)            | Single, 2 × 29,500 (25)                                     |
| 0          | 59,000 (50)                        | 42 (1,470)                                 | 1,908 (12,000)                   | 477 (3,000)                      | 2,172 (315)              | 6,895 (1,000)            | Single, 2 × 29,500 (25)                                     |
| ი          | 118,000 (100)                      | 178 (6,280)                                | 3,816 (24,000)                   | 954 (6,000)                      | 1,034 (150)              | 6,895 (1,000)            | Multiple, 2 × 29,500 (25),<br>1 × 59,000 (50)               |
| 4          | 118,000 (100)                      | 83 (2,930)                                 | 3,816 (24,000)                   | 954 (6,000)                      | 2,172 (315)              | 6,895 (1,000)            | Multiple, 2 × 29,500 (25),<br>1 × 59,000 (50)               |
| 5          | 236,000 (200)                      | 356 (12,570)                               | 7,632 (48,000)                   | 1,908 (12,000)                   | 1,034 (150)              | 6,895 (1,000)            | Multiple, 2 × 29,500 (25),<br>3 × 59,000 (50)               |
| 9          | 236,000 (200)                      | 166 (5,860)                                | 7,632 (48,000)                   | 1,908 (12,000)                   | 2,172 (315)              | 6,895 (1,000)            | Multiple, 2 × 29,500 (25),<br>3 × 59,000 (50)               |
| ¹Sm³/h, si | tandard cubic meters pe            | er hour; MMscfd, million standard c        | cubic feet per day; acfm         | i, actual cubic feet per r       | minute; bbl, oilfield ba | rrels; kPag, kilopasca   | I gauge; psig, pounds per                                   |

Table 1 Case summary for the large-scale enhanced oil recovery surface facility study<sup>1</sup>

<sup>1</sup>Sm³/h, standard cubi square inch gauge.

for the fluids entering the facility was assumed to be 37.8 °C (100 °F) in all cases. Although actual fluid temperatures coming in from the field may be lower, these facilities typically include heat integration to warm the fluids entering the facility and to cool the gas leaving the  $\rm CO_2$  compressors. Details on fluid temperatures are not addressed in this report.

The selected EOR  $CO_2$  production (recycle) range was 59,000 to 236,000 Sm<sup>3</sup>/h (50 to 200 MMscfd), the assumed minimum and maximum  $CO_2$  production rates for large-scale facilities in the ILB. The gas was assumed to be mostly  $CO_2$  but also to contain hydrocarbons, as shown in Table 2.

The first 59,000 Sm3/h (50 MMscfd) of recycled CO<sub>2</sub> gas flow in each case will be processed with two 29,500 Sm3/h (25 MMscfd) compressors operating in parallel. This setup provides additional operational flexibility at reduced throughput conditions as compared with installing one 59,000 Sm3/h (50 MMscfd) compressor. Afterward, each additional increment of 59,000 Sm3/h (50 MMscfd) will be processed with one additional 59,000 Sm<sup>3</sup>/h (50 MMscfd) compressor. As the production rate increases over several years, additional compressors and other equipment will be added to accommodate increases in produced gas and oil rates. Water production rates are typically at their highest right after changing from waterflood to CO<sub>2</sub> flood operations, so it has been assumed in this report that an existing waterflood field in the ILB would already have adequate water processing, storage, and disposal equipment before beginning a CO<sub>2</sub> flood.

The central facility phased approach of installing additional, nearly identical sets of equipment, each with a 59,000

Sm<sup>3</sup>/h (50 MMscfd) capacity per phase, as the CO<sub>a</sub> recycle and oil production rates increase over the life of the EOR flood is an approach that is often used in CO<sub>2</sub> EOR operations. Deployment of the central facility components in phases is sometimes related to development of the oil field in EOR flood phases. The central facility phased approach might result in a somewhat higher overall total cost at the end of facility build-out to full capacity as compared with installing fewer pieces of equipment with larger unit capacities at the beginning of the operation that are capable of processing the ultimate expected facility CO, recycle, produced oil, and produced water flow rates. However, the advantage of delaying much of the capital expenditures by several years is often a tradeoff that favors a phased approach. The phased approach also provides operation of equipment closer to design capacities (avoiding high turndown operations with lower efficiencies) and reduces the risk of purchasing equipment or equipment capacity that might not be needed if actual EOR flood operations differ from original projections. It is beyond the scope of this report to evaluate the pros and cons of the phased approach that would likely be driven by field-specific considerations in any case. Nonetheless, it is important to point out that the phased approach selected by Trimeric for this evaluation and the resulting costs that basically scale linearly with throughput capacity might not reflect the approach that would be taken by an EOR flood operator for large-scale CO<sub>a</sub> recycle facility design in all cases.

### **Oil and Water Production Rate** Assumptions

The oil and water production rates provided in Table 1 for the large-scale EOR cases were based on an 80% water/20% oil ratio on a barrels-per-day basis with the total liquid flow rate scaled based on the  $CO_2$  per recycle rate (MMscfd). The oil and water production rates are based on recent ILB  $CO_2$  EOR reservoir simulation estimates performed by the ISGS. The peak production ratios were used for equipment sizing, but it was understood that the ratios could vary throughout the lifetime of the EOR operation and that the ratios would vary from field to field.

The peak water capacity was based on a water-to-gas ratio of 0.00134 m3/m3 (0.24 bbl/Mscf [oilfield barrels/thousand standard cubic feet]), and the peak oil capacity assumes an oil-to-gas ratio of 0.00034  $m^3/m^3$  (0.06 bbl/Mscf). These ratios are approximately 52% and 69% of the values used with the small-scale EOR cases, respectively. Thus, less water and oil were assumed to be produced for the largescale EOR facilities than would have been estimated if the same ratios had been used as with the small-scale applications in the previous study. The estimated oil storage requirements and water disposal costs were 48% and 31% lower, respectively, than if they had been estimated using the same water-to-gas and oil-togas ratios as in the small-scale study.

### **Process Configurations**

A typical EOR surface facility has three primary functions:

- 1. To separate the produced gas (primarily CO<sub>2</sub> and hydrocarbons) from the produced liquids.
- 2. To compress the produced gas for reinjection or for distribution in a pipeline.
  - a. To remove hydrocarbons to generate revenue or, if necessary, for efficient compression and

Table 2 Assumed peak characteristics of the produced gas<sup>1</sup>

| Component        | Value                            |
|------------------|----------------------------------|
| Carbon dioxide   | 97.8 mol. %                      |
| Methane + ethane | 1.5 mol. %                       |
| NGLs             | 0.7 mol. %                       |
| NGLs             | 0.03 L/m <sup>3</sup> (0.22 GPM) |

<sup>1</sup>NGLs, natural gas liquids, i.e., propane and heavier hydrocarbons. The NGL content in gases is typically characterized in terms of the gallons of recoverable hydrocarbons in the gas per thousand standard cubic feet of gas (GPM).

subsurface operations, which depend on the hydrocarbon composition and concentration in the CO<sub>2</sub>.

- b. To dehydrate the recycle gas, if necessary, to meet site-specific requirements for reinjection or pipeline specifications for CO<sub>2</sub>.
- 3. To separate produced water and oil, with storage, discharge, or both for the liquids.
  - a. To capture or treat low-pressure gas, if necessary, from flash gas from liquids during the pressure let-down steps.
  - b. To apply chemical treatment to break the oil-water emulsion for improved liquids separation. (Heating instead of or in addition to chemical treatment is used to separate oil and water at some EOR facilities.)

The equipment required to accomplish these three primary surface facility functions varies depending on the properties of the inlet gas, such as pressure in this evaluation as well as composition in other applications, the required gas discharge pressure, and the flow rates of the inlet gas, oil, and water streams. Process flow diagrams for the six cases listed in Table 1 are provided in Appendix A, and the detailed equipment design and cost estimates are described in the following section. In Appendix B, the individual facility component costs are listed in tables so that the impact on the overall cost of the facility of removing or adding a particular component can be evaluated.

### EQUIPMENT DESIGN AND COST ANALYSIS SUMMARY

This section describes the general approach used to size and select surface equipment for the large-scale EOR facilities. Included here are the equipment capital costs and the anticipated fluid processing rates for the plants. Important differences from the small-scale EOR evaluation conducted previously are also noted. The economic results from the large-scale EOR study are also presented.

### **Equipment Sizing**

The surface equipment for the large-scale EOR facilities was sized using different

methods, depending on the type of equipment. This section discusses those methods and presents other important design criteria that could potentially affect the cost of the equipment.

### Separators

Various separators are used in the EOR surface equipment. The separator types can be described briefly as follows:

- Slug catcher. This vessel is used to separate the produced gas from the oil and water at the inlet to the facility. The gas exits the top of the vessel and flows to the high-pressure compressor train, whereas the oil and water exit in a combined stream to downstream separation vessels. The slug catcher operates at a pressure slightly lower than the pressure of the wellhead (1.034 and 2.172 kPag [150 and 315 psig], depending on the inlet pressure for each case). The pressure drop in the wellhead choke and in the gathering lines brings the fluids to the central facility. The slug catcher is typically a horizontal vessel, sized to have a length-to-diameter ratio of about 3 and a liquid residence time of 7.5 min.
- Free water knockout. This horizontal vessel is used to separate the bulk of the water from the oil. The vessel operates at a low pressure of approximately 172 kPag (~25 psig), and some dissolved CO, will evolve as a gas and be sent to the low-pressure suction scrubber. The free water knockout is typically a horizontal vessel. A horizontal free water knockout is shown in Figure 1. In many parts of the United States, heat from burning natural gas, sometimes transferred to the free water knock-out via use of an intermediate heat transfer fluid, is used to help separate the oil from the water. However, according to a discussion between Trimeric and Ken Hake of Baker Hughes (personal communication, July 15, 2015), the separation of oil and water by chemical addition is the most common approach in the ILB and is the one assumed in this report. The free water knockout vessel was sized by using an approach in the literature for three-phase separators (Monnery and Svrcek1994).
- Demulsifier. In this vessel, the water and oil phases separate because chemicals are added in the upstream process to break any oil-water emulsions. A small amount of CO<sub>2</sub> gas may evolve from the liquids, and this gas is also sent to the low-pressure suction scrubber. A pressure drop of 6.9 kPa (1 psi) was assumed while transferring the liquids from the free water knockout to the demulsifier. Depending on site operations, the actual pressure drop might be in the range of 34.5 to 68.9 kPa (5 to 10 psi), but these differences will not affect these early phase designs and cost esti mates. The demulsifier vessel typically has a horizontal orientation and is similar in appearance to the horizontal free water knockout vessel shown in Figure 1. Sometimes heat is applied for this type of separation (i.e., heater-treater vessels) when natural gas, fuel gas, electricity, or some form of waste heat input is available, but discussions with those experienced in oilfield operations in the ILB suggest that a chemical separation approach is used almost exclusively in ILB oil production facilities (Ken Hake of Baker Hughes, personal communication, July 15, 2015). The demulsifier was sized to have a length-to-diameter ratio of approximately 3 and a residence time of 30 min. A longer residence time is used in this vessel to obtain a high degree of separation of the oil and water phases.
- *High-pressure suction scrubber*. This vertical vessel is used to prevent liquids from entering the compressor cylinders and is typically made of carbon steel with an internal corrosion-resistant coating or stainless steel. Figure 2 shows an example of a vertical vessel used as a compressor suction scrubber and the compressor itself. The suction scrubber is used (1) to remove liquids that may condense in the line coming from the top of the slug catcher as well as any atomized drops or carryover, and (2) to remove any slugs of liquid from the slug catcher in upset conditions or if unexpectedly high fluid volumes come to the facility. The high-pressure suction scrubber will operate at a facility inlet pressure of either 1,034 or 2,172



Figure 1 Typical horizontal free water knockout vessel. The horizontal slug catcher and demulsifier vessels are similar in appearance. Photograph courtesy of Denbury Onshore.



**Figure 2** Typical vertical vessel high-pressure suction scrubber and compressor. Typical low-pressure suction scrubbers and compressors are similar in appearance. Photograph courtesy of Denbury Onshore.

kPag (150 or 315 psig). The vendor quotes that were used to estimate the purchased costs for the large-scale compressors in this report included this suction scrubber. Therefore, sizing or estimating the costs for this equipment was not needed.

• Low-pressure suction scrubber. This vertical vessel is used to prevent any liquids from entering the lowpressure compressor cylinders. The vessel is typically made of carbon steel with an internal corrosionresistant coating or stainless steel. The low-pressure compressor train is typically added at an EOR facility when enough flash gas is present to justify the cost of the low-pressure train, which is used to feed these gases to the suction of the highpressure compression system. In all six cases in this large-scale EOR evaluation, the flash gas rates were high enough to justify the addition of a low-pressure compressor or compressors. The low-pressure suction scrubber operates at a low pressure of approximately 165 kPag (~24 psig). This pressure might be slightly lower depending on the actual operating conditions, but these differences will not affect the early-phase designs and cost estimates.

The material of construction for the slug catcher, free water knockout, and demulsifier was assumed to be coated carbon steel. The dimensions of these separators were based on the produced-gas rate and the oil and water capacities for Cases 1 and 2. Multiple separators of the same size as those in Cases 1 and 2 were then used to handle the higher flow conditions for Cases 3 through 6.

### **Chemical Injection System**

Chemicals are added to the inlet of the slug catcher to break any oil-water emulsions and further remove water from the oil. In fact, according to discussions between Trimeric and Ken Hake of Baker Hughes (personal communication, July 15, 2015), the chemicals might be added further upstream of the facilities discussed in this report to allow them more contact time to mix with the produced fluids. The demulsifier chemical will be added to give a concentration of 90 ppmv (parts per million by volume) of demulsifier in the oil-water mixture, as recommended by Ken Hake as a starting point for use in this evaluation. However, actual oil and water samples and laboratory testing will be used to determine the optimal additive type(s) and concentration(s) for a specific application. The final separation of oil and water will occur in the demulsifier vessel. The demulsifier chemical storage tank was sized to hold a 14-d supply of demulsifier chemical. The demulsifier injection pump was sized to transfer the appropriate amount of chemical for Cases 1 and 2. Multiple chemical injection pumps and demulsifier storage tanks were assumed for Cases 3 through 6.

### **Oil Storage Tank**

Oil production was assumed to start out initially at low rates, peak, and then steadily decrease until the end of life for the field. The oil would be stored in tanks until it could be piped off-site. For Cases 1 and 2, it was assumed that 1,431 m<sup>3</sup> (9,000 bbl) American Petroleum Institute-style steel tanks would be used to hold 3 d of oil production at the peak capacity rate. Multiple oil storage tanks were assumed for Cases 3 through 6. The oil storage requirement may be less, depending on the sales options available at the site.

### Water Storage Tank

For the large-scale EOR facilities, water storage tanks were excluded from the study. This was because the fields were assumed to have been converted from an existing waterflood operation and would therefore already have existing water storage and disposal equipment. Water production generally decreases during  $CO_2$  EOR, so fields with an existing waterflood may not need new water storage or handling facilities. The existing waterhandling equipment was assumed to be adequate.

### **Air Coolers**

Air-cooled heat exchangers are used to remove the heat of compression from the  $CO_2$  stream after each stage of compression in both the high- and low-pressure trains although, as mentioned,  $CO_2$  EOR facilities at this large scale are likely to incorporate heat integration to help cool the compressed  $CO_2$  and transfer the heat to improve fluid separations. To simplify this early-stage evaluation, all heat of compression was assumed to be removed by air coolers. The air-cooled heat exchangers were not included in the vendor quotes that were used to estimate the compressor costs for the large-scale EOR cases. Thus, the exchanger duties were estimated from modeling using the WinSim Design II software. The air coolers were assumed to have stainless steel material in the tubes and in other areas in contact with the wet CO<sub>2</sub> gas.

### CO<sub>2</sub> Compressor Trains

The high-pressure and low-pressure CO<sub>a</sub> compressor trains were first modeled with WinSim's Design II software using the Peng-Robinson equation of state to obtain an initial estimate of the horsepower requirements. The ISGS had expressed an interest in identifying the highest possible single-compressorunit throughput capacities for the two inlet pressures. Trimeric worked with two equipment supplier contacts, Jason Sowels at Reagan Power and Compression and Dave Morse at Dresser-Rand (personal communication, July 2015), to determine the maximum feasible compressor sizes for the 1,034 to 6,895 kPag (150 to 1,000 psig) and the 2,172 to 6,895 kPag (315 to 1,000 psig) compression ratios. On the basis of input from these highly experienced contacts, 59,000 Sm<sup>3</sup>/h (50 MMscfd) was judged to be the maximum expected throughput for the largest Dresser-Rand 7HOSS6 or similar Ariel KBZ6 frames for the higher compression ratio case with 1,034 kPag (150 psig) of suction pressure. Sowels and Morse identified single-unit options with throughputs of 59,000 Sm<sup>3</sup>/h (50 MMscfd) and 88,500 Sm3/h (75 MMscfd) for the lower compression ratio case with 2,172 kPag (315 psig) of suction pressure. Trimeric and the two contacts concluded that the 59,000 Sm3/h (50 MMscfd) throughput was a more logical fit for both suction pressure cases because it fit in even increments with the recycle rates of 59,000 Sm3/h (50 MMscfd), 118,000 Sm<sup>3</sup>/h (100 MMscfd), and 236,000 Sm<sup>3</sup>/h (200 MMscfd) in this evaluation.

Trimeric expected that the higher compression ratio case with 1,034 kPag (150 psig) of suction pressure would require two stages of compression, which was confirmed by the equipment suppliers. Trimeric expected that the lower

compression ratio case with 2,172 kPag (315 psig) of suction pressure could be achieved in a single-stage compressor. However, the equipment suppliers also proposed a two-stage compressor for the lower compression ratio case. Trimeric reviewed this option with the contacts, who explained that at these high flow rates and these suction and discharge pressure conditions, a single-stage configuration on the largest frames, such as the Dresser-Rand 7HOSS6, would actually result in a lower unit capacity and a higher power requirement per standard cubic meter per hour (million standard cubic feet per day) of CO<sub>2</sub> throughput than if the equipment were configured for a two-stage operation.

Trimeric also discussed the low compression ratio application with two other industry contacts, Casey Saunier and Dirk Dailey, both with Pelstar Mechanical Services (personal communication, July 2015). Saunier and Dailey provided several reasons why they agreed that two stages of compression would be preferable in this application. They pointed out that any decrease in suction pressure, increase in suction temperature, increase in discharge pressure, or changes in the gas composition could lead to problems with a single-stage compressor in this application, including excessive cylinder discharge temperatures, high rod-load conditions, or exceeding the pressure relief valve set points. They offered that a suction pressure of at least 2,760 kPag (400 psig), suction temperatures in the range of 10 to 21 °C (50 to 70 °F), or some related combination of higher suction pressure and lower suction temperature would be needed to specify a single-stage compressor with adequate design margins for this application. Using two stages of compression for the high suction pressure case resulted in another difference from the 2013 evaluation for the smaller compressors. In those smaller facility cases, which could operate on compressor frames with a greater margin between the operating conditions and the maximum rod-load limits, Trimeric assumed that the higher suction pressure case with 2,172 kPag (315 psig) of suction pressure and 6,895 kPag (1,000 psig) of discharge pressure could be accommodated with single-stage compressors.

The construction material for components on the suction side of the compressor cylinders was assumed to be a combination of cladded or coated carbon steel and solid stainless steel. Coated carbon steel or stainless steel is typically used on the suction side, where the gas is saturated and water could be present from condensation or carryover. Carbon steel is typically used on the discharge side of the compressor cylinders because the discharge is hot, near 149 °C (300 °F), and therefore well above the water dew point during normal operation.

Two 29,500 Sm3/h (25 MMscfd) compressors would be installed in parallel to handle the 59,000 Sm3/h (50 MMscfd) of CO<sub>2</sub> gas flow rate for Cases 1 and 2. Doing so would provide additional operational flexibility at reduced throughput conditions as compared with installing one 59,000 Sm<sup>3</sup>/h (50 MMscfd) compressor. As discussed, a single 59,000 Sm3/h (50 MMscfd) reciprocating compressor is the largest size recommended for this application. Therefore, additional compressors of this size would be installed to handle the additional gas flow rates shown in Table 1 for Cases 3-6. The additional 59,000 Sm3/h (50 MMscfd) compressors were assumed to be installed over time as the gas production rate increased throughout the life of the field. Many companies that operate CO<sub>2</sub> EOR facilities elect to defer the relatively high capital cost of compression and related equipment purchases until such time as the amount of CO<sub>2</sub> returning with the produced oil and water requires additional CO<sub>a</sub> compression equipment capacity.

If the compressor train is installed with a discharge-to-suction recycle capability, it can compress gas at flow rates as low as approximately 25% of the design gas flow rate. Variable-volume clearance pockets, cylinder head unloading mechanisms, and variable-frequency drives (primarily for smaller units) can also be used to reduce the throughput in these types of reciprocating compressors. Compressor operating costs were based on the peak product throughput; however, the energy efficiency may be lower at times when the compressors are not fully loaded. Low-pressure compression trains would presumably be used to send flash gases from the free water knockout and demulsifier to the suction of the high-pressure compression train.

### Dehydration

Costs were included for dehydration of the compressed CO<sub>2</sub> before reinjection. Dehydration would likely be needed if the added costs to use corrosion-resistant materials downstream of the compressors offset the cost of dehydration or if the CO<sub>2</sub> had to go through a common carrier pipeline after compression. Without dehydration, the CO<sub>2</sub> leaving the compressor train could be saturated with water at some conditions. The CO<sub>2</sub> would cool as the gas flowed through aboveground and underground piping, increasing the potential for water to condense and cause increased corrosion. The injection pressure anticipated for ILB EOR facilities (6,895 kPag [1,000 psig]) is too low to take advantage of the increased water-holding capacity of CO<sub>2</sub> that occurs at pressures exceeding 6,895 kPag (1,000 psig). The possibility of forming CO<sub>0</sub>water solid hydrates may also be an issue that requires the dehydration of CO<sub>2</sub>.

As a simplification, it was assumed in all cases that dehydration would take place at the discharge of the compressor train at high pressure. However, triethylene glycol losses into the CO<sub>2</sub> stream at 6,895 kPag (1,000 psig) might begin to become detrimental such that glycerol might be required instead. Alternatively, triethylene glycol dehydration could be performed between the first and second stages of compression. In any case, these detailed design decisions are unlikely to affect the cost estimates provided in this early-stage conceptual evaluation. The cost of dehydration is shown separately in Appendix B, Major Equipment Lists and Purchased and Installed Costs for Cases 1-6, to show the cost impact of this unit operation and to facilitate the removal of these costs if dehydration is not required.

A single dehydration unit should be able to treat the gas flow in Cases 1 and 2 (59,000 Sm<sup>3</sup>/h [50 MMscfd]) as well as in Cases 3 and 4 (118,000 Sm<sup>3</sup>/h [100 MMscfd]). For the highest gas flow rate assumed in Cases 5 and 6 (236,000 Sm<sup>3</sup>/h [200 MMscfd]), two 118,000 Sm<sup>3</sup>/h (100 MMscfd) dehydration units were used in the process flow scheme. A single dehydration unit could possibly also be provided for the highest gas flow rate cases, but this difference would not have a significant impact on the cost estimates in this early-stage conceptual evaluation.

### Buildings

Buildings to house compressors, controls, chemicals, and maintenance equipment were included in the EOR facility. The estimated size of the building(s) was determined based on past experience with other projects.

### **Capital Costs**

This section describes the approach used to estimate the purchased and installed costs for the EOR facilities evaluated in this study. The purchased equipment costs were obtained from a combination of vendor quotes and costing software. The In-Plant Cost Estimator software package from AspenTech was used to estimate the purchased equipment costs for some of the process equipment. The In-Plant Cost Estimator costs are from the first quarter of 2015. The purchased costs were adjusted to a January 2015 cost basis (the most recent index available at the time of this evaluation) using published plant cost indices (Chemical Engineering Plant Cost Index, Chemical Engineering Magazine 2015). The list below shows the source of the purchased equipment costs by equipment type:

- Separators (slug catcher, free water knockout, and demulsifier)—In-Plant Cost Estimator. The high- and low-pressure suction scrubbers were included in cost estimates for the CO<sub>2</sub> compressor trains, so the costs for these vessels were not estimated separately.
- Chemical injection pump—In-Plant Cost Estimator
- Chemical injection tank—in-house vendor data

- Oil storage tanks—In-Plant Cost Estmator
- Water storage tanks—not required because the water storage and disposal equipment were already assumed to exist from the waterflood operations before conversion to CO<sub>2</sub> flooding
- CO<sub>2</sub> compressor train interstage air coolers—scaled from a similar air cooler quote in 2013
- CO<sub>2</sub> compressor trains—In-Plant Cost Estimator and a vendor quote from 2014
- Dehydration—scaled from vendor quotes for other CO<sub>2</sub> projects obtained from 2008 to 2015
- Building—In-Plant Cost Estimator

The installation costs for purchased equipment were estimated using typical factors as a percentage of the purchased equipment cost (Morris and Williams 2001). The sum of the purchased equipment cost and the installation cost is the installed equipment cost. The tables in Appendix B show the detailed equipment sizes and the estimated purchased and installed costs for the individual equipment components needed for the six cases. Table 3 provides a summary of the total purchased and installed costs for each case.

The total installed costs represent the estimated cost for installing and connecting the necessary pieces of equipment in an existing facility that already has a basic infrastructure in place (e.g., buildings, electrical power, roads, and prepared plot areas). The FCI estimates provided in the Fixed Capital Investment section of this report represent the total costs for a new facility that requires the installation of basic infrastructure in addition to the EOR equipment.

### Differences in Small- and Large-Scale Enhanced Oil Recovery Studies

The small-scale EOR evaluation conducted previously has several important differences from the large-scale EOR cases evaluated in this report. These differences are summarized below for reference.

### **Oil and Water Production Ratios**

The oil-to-gas and water-to-gas production ratios were higher for the small-scale EOR cases than for the larger  $CO_2$  flow cases in this study. This means that the oil storage and water disposal requirements are less for the large-scale EOR cases than if we had used the same ratios from the previous study.

### CO<sub>2</sub> Compressor Trains

High- and low-pressure suction scrubbers were included in the cost estimates for the large-scale compressor trains; however, the interstage air coolers were not. This is different from the smallscale EOR study, in which the coolers were included in the compressor quote from the compression vendor and the high- and low-pressure suction scrubbers were excluded. For this reason, different equipment sizing and cost estimates were required in the two studies to estimate the overall compressor costs, including suction scrubbers and coolers. In addition, the compressors used

|      | production,   | Water          | Oil            | Facility inlet |                 |                 |
|------|---------------|----------------|----------------|----------------|-----------------|-----------------|
|      | Sm³/h         | production,    | production,    | pressure, kPag | Total purchased | Total installed |
| Case | (MMscfd)      | m³/d (bpd)     | m³/d (bpd)     | (psig)         | cost, \$        | cost, \$        |
| 1    | 59,000 (50)   | 1,908 (12,000) | 477 (3,000)    | 1,034 (150)    | 7,458,000       | 11,538,000      |
| 2    | 59,000 (50)   | 1,908 (12,000) | 477 (3,000)    | 2,172 (315)    | 6,673,000       | 10,374,000      |
| 3    | 118,000 (100) | 3,816 (24,000) | 954 (6,000)    | 1,034 (150)    | 13,843,000      | 21,343,000      |
| 4    | 118,000 (100) | 3,816 (24,000) | 954 (6,000)    | 2,172 (315)    | 12,301,000      | 19,058,000      |
| 5    | 236,000 (200) | 7,632 (48,000) | 1,908 (12,000) | 1,034 (150)    | 27,214,000      | 42,114,000      |
| 6    | 236,000 (200) | 7,632 (48,000) | 1,908 (12,000) | 2,172 (315)    | 24,157,000      | 37,588,000      |

| Table 3 | Total | purchased | and | installed | costs |
|---------|-------|-----------|-----|-----------|-------|
|         |       | 0         | ~   |           |       |

<sup>1</sup>Sm<sup>3</sup>/h, standard cubic meters per hour; MMscfd, million standard cubic feet per day; bpd, barrels per day; kPag, kilopascal gauge; psig, pounds per square inch gauge.

to increase the pressure of the  $CO_2$  from 2,172 to 6,895 kPag (315 to 1,000 psig) for the large-scale EOR cases required two stages of compression (per vendor input) instead of the single-stage compressors selected for the same suction and discharge pressure requirements in the small-scale EOR facility evaluation.

### Water Storage Tanks

Capital costs for water storage tanks were not included with the large-scale EOR cases because they were already assumed to exist from waterflood operations. Carbon steel water tanks were included and sized to hold 3 d of capacity at the peak water rate for the small-scale EOR facility evaluation. However, operating costs for water disposal were included for both the small- and large-scale EOR facilities based on an assumed cost of \$1/ bbl of produced water. Trimeric assumed this value after discussing water disposal costs with one ILB oilfield operator and comparing the operator's input with water disposal cost data from other Trimeric projects. Operators often arrange for on-site disposal of the produced water or use it in the flood management of an EOR field to reduce costs for water disposal.

### **Natural Gas Liquid Recovery**

Natural gas liquid recovery was not evaluated for the large-scale EOR cases because in the previous work, we concluded that NGL recovery was not economically justified, given the lean NGL content of the gas expected from the ILB  $(0.03 \text{ L/m}^3 [0.22 \text{ GPM}])$ , even at the high  $CO_2$  flow rates used in the large-scale facility evaluation. The NGL content in gases is typically characterized in terms of gallons of recoverable hydrocarbons in the gas per thousand standard cubic feet of gas (GPM).

### **Demulsifier Chemicals**

In the small-scale EOR evaluation, a demulsifier concentration of 1,000 ppmv in only the oil phase was assumed based on past project experience. The resulting concentration in the total liquid volume of the oil and water phases would be approximately 200 ppmv, which is about 2.2 times the amount used with the largescale EOR cases. The 90 ppmv concentration based on the total liquid volume (oil plus water) should be considered more up to date and accurate because it was recently obtained from a vendor specifically for the ILB large-scale facility evaluation (Ken Hake of Baker Hughes, personal communication, July 2015). A higher cost for the demulsifer chemicals was also used in this work (\$24/gal) than in the small-scale EOR evaluation (\$10/ gal). The difference in concentration bases and costs resulted in an increase in annual demulsifer chemical costs of 8% in the large-scale evaluation. The chemical storage capacity for the large-scale EOR cases was approximately half that required if we had used the same concentration basis as in the small-scale EOR work. However, this expense is insignificant in terms of the overall costs for the EOR facilities.

### Dehydration

Capital costs for dehydration in this report were based on more recent vendor quotes for units treating  $CO_2$  streams in the larger flow range.

### **Operating Cost Information**

Operating cost information for the six cases is shown in Table 4. The information is separated into two categories: variable costs (with the capacity utilization factor) and fixed costs. The operating cost information and bases are discussed in this section so that they can be combined with any field-wide operating costs developed by others.

As shown in Table 4, a capacity utilization factor of 95% was assumed for the variable costs. The capacity utilization factor takes into account both the on-stream factor, which is the total percentage of time the facility is operating, and the capacity factor, which is the average percentage of the production rate compared with the design production rate. The 95% value was based on data collected by Charles Monson at the ISGS for several facilities in the ILB (Monson 2012). The electricity usage for the major equipment is also shown. Compression power ranged from 85% to 95% of the total electricity demand at the EOR facilities. The compression power includes the power required for both the high-pressure and the low-pressure compression trains. The annual electricity cost is estimated based on an assumed electricity cost of \$0.09/

kWh. The peak water rate is shown so that disposal costs for off-site disposal can be estimated (\$1/bbl assumed). The peak oil rate is given to facilitate the estimation of transportation fees (not included). The total dehydration operating costs are included so that the operating expenses can be estimated for the entire EOR facility. The demulsifier chemical cost is \$24/ gal based on recent vendor input (Ken Hake of Baker Hughes, personal communication, July 2015).

The fixed costs include an estimate of the number of operators required to run the facility and an estimate of the supervisor labor (assumed to be 20% of the operating labor costs). Maintenance expenses are estimated at \$40/(hp-yr) based on experience with these types of compressor facilities. The plant operating overhead is assumed to be 75% of the operating and supervisor costs (typical factor). The fixed costs do not include the capacity utilization factor.

The total operating costs (variable and fixed items) ranged from \$7.7 million for Case 2 with 59,000 Sm3/h (50 MMscfd) of CO<sub>2</sub> flow and an inlet pressure of 2,172 kPag (315 psig) to \$35.3 million for Case 5 at 236,000 Sm3/h (200 MMscfd) of CO2 flow and an inlet pressure of 1,034 kPag (150 psig). The cost for produced water disposal represents approximately 48% to 58% of the variable operating costs, and the annual electricity cost accounts for another 29% to 41%, depending on the inlet gas pressure (2,172 kPag [315 psig] or 1,034 kPag [150 psig], respectively). Approximately 32% to 76% of the fixed operating costs resulted from annual compressor maintenance, with the remaining amount pertaining to labor and overhead expenses.

### **Fixed Capital Investment**

The purchased equipment costs for the EOR facility were multiplied by a factor of 3 to estimate the FCI cost. This factor accounts for the costs of items such as purchased equipment costs, purchased equipment installation, instrumentation and controls, piping, electrical systems, engineering and supervision, construction expenses, contractors' fees, and contingency. A multiplier of 3 times the purchased equipment costs is typically used to estimate the FCI for a mix of vendor-provided skid-mounted equipment,

### Table 4 Operating cost summary<sup>1</sup>

| Operating cost                         |                                     |           |           | C          | Case       |            |            |
|--|-------------------------------------|-----------|-----------|------------|------------|------------|------------|
| information                            | Unit                                | 1         | 2         | 3          | 4          | 5          | 6          |
| Variable costs (includes ca            | pacity utilization factor)          | )         |           |            |            |            |            |
| Capacity utilization factor            | %                                   | 95        | 95        | 95         | 95         | 95         | 95         |
| Electricity usage                      | kW                                  | 4,240     | 2,524     | 8,483      | 5,051      | 16,970     | 10,105     |
| Motor efficiency                       | %                                   | 95        | 95        | 95         | 95         | 95         | 95         |
| Annual electricity cost                | \$/yr                               | 3,518,700 | 2,094,800 | 7,040,300  | 4,191,800  | 14,083,400 | 8,386,000  |
| Chemical injection                     | \$/gal                              | 24        | 24        | 24         | 24         | 24         | 24         |
| Chemical injection rate                | gal/d                               | 54        | 54        | 108        | 108        | 215        | 215        |
| Annual chemical<br>injection cost      | \$/yr                               | 472,000   | 472,000   | 944,000    | 944,000    | 1,887,000  | 1,887,000  |
| Produced water<br>disposal             | \$/bbl                              | 1         | 1         | 1          | 1          | 1          | 1          |
| Produced water<br>disposal rate        | bpd                                 | 11,400    | 11,400    | 22,800     | 22,800     | 45,600     | 45,600     |
| Annual produced water<br>disposal cost | \$/yr                               | 4,161,000 | 4,161,000 | 8,322,000  | 8,322,000  | 16,644,000 | 16,644,000 |
| Annual dehydration cost                | \$/yr                               | 515,000   | 515,000   | 887,000    | 887,000    | 1,450,000  | 1,450,000  |
| Oil transport capacity                 | bpd                                 | 2,850     | 2,850     | 5,700      | 5,700      | 11,400     | 11,400     |
| Total variable operating costs         | \$/yr                               | 8,666,700 | 7,242,800 | 17,193,300 | 14,344,800 | 34,064,400 | 28,367,000 |
| Fixed costs                            |                                     |           |           |            |            |            |            |
| Operating labor                        | Full-time equivalent                | 2         | 2         | 2          | 2          | 2          | 2          |
| Cost of labor                          | \$/h                                | 29        | 29        | 29         | 29         | 29         | 29         |
| Operating labor cost                   | \$/yr                               | 146,600   | 146,600   | 146,600    | 146,600    | 146,600    | 146,600    |
| Supervisor labor                       | % of operating<br>labor cost        | 20        | 20        | 20         | 20         | 20         | 20         |
| Supervisor labor cost                  | \$/yr                               | 29,400    | 29,400    | 29,400     | 29,400     | 29,400     | 29,400     |
| Compressor<br>maintenance cost factor  | \$/(hp-yr)                          | 40        | 40        | 40         | 40         | 40         | 40         |
| Compressor<br>horsepower               | hp                                  | 5,984     | 3,562     | 11,973     | 7,128      | 23,951     | 14,260     |
| Annual compressor<br>maintenance cost  | \$/yr                               | 239,400   | 142,500   | 479,000    | 285,200    | 958,100    | 570,400    |
| Plant operating<br>overhead            | % of operating +<br>supervisor cost | 75        | 75        | 75         | 75         | 75         | 75         |
| Plant operating<br>overhead cost       | \$/yr                               | 132,000   | 132,000   | 132,000    | 132,000    | 132,000    | 132,000    |
| Total fixed operating costs            | \$/yr                               | 547,400   | 450,500   | 787,000    | 593,200    | 1,266,100  | 878,400    |
| Total operating costs                  | \$/yr                               | 9,214,100 | 7,693,300 | 17,980,300 | 14,938,000 | 35,330,500 | 29,245,400 |

<sup>1</sup>bbl, oilfield barrels; bpd, barrels per day.

on-site assembly (separators, tanks, etc.), and field fabrication of interconnecting piping.

As noted in the Capital Costs section, the FCI represents the total cost for a new facility that requires the installation of all basic infrastructure in addition to the EOR equipment. Trimeric considers these cost estimates a study estimate (factored estimate) that is based on the knowledge of major items of equipment and that has an expected accuracy of  $\pm 30\%$  (Peters et al. 2003). Table 5 summarizes the estimated FCI for the surface equipment for all six cases. Observations regarding these cost data are described below.

### The General Fixed Capital Investment Cost Relationship

As shown in Table 5, the FCI ranged from \$20 million for Case 2 with 59,000 Sm<sup>3</sup>/h (50 MMscfd) of produced gas to as high as \$81.6 million for Case 5 with 236,000 Sm<sup>3</sup>/h (200 MMscfd) of produced gas. Compression represents approximately 50% to 60% of the overall capital costs, followed by dehydration at approximately 20% and the separation of liquid phases and cooling of the gas phase totaling approximately 15%.

Figure 3 graphically represents the estimated FCI for the large-scale EOR facilities. As explained, the costs scale fairly linearly with the CO<sub>2</sub> recycle rate because of the modular approach assumed for the construction of these large-scale EOR recycle facilities. In addition, differences in the FCI are fairly minimal because the compressor vendors that Trimeric contacted regarding these cases recommended two-stage compressors for both suction pressure conditions. More details on this topic are provided in the CO<sub>a</sub> Compressor Trains discussion in the Equipment Design and Cost Analysis Summary section of this report.

### Fixed Capital Investment Model Development

A model (see Equation 1) was developed to estimate the FCI based on the cost estimates from the previous small-scale EOR facility evaluation and the large-scale EOR cases summarized in this report. A simple model was developed to estimate the FCI (first quarter of 2015) for the oil storage tanks based on the peak oil production rate and that for the rest of the surface equipment based on the peak  $CO_2$  recycle rate as a function of inlet pressure ranging from 1,034 to 2,172 kPag (150 and 315 psig) with a discharge pressure of 6,895 kPag (1,000 psig). The FCI cost estimates derived from Equation 1 do not include any costs for water storage tanks for the reasons already noted:

 $FCI = (379,810 \times CO_2 \text{ Rate} + 2,851,322) \\ \times (1.0955 - 0.0006 \times \text{Pressure}) + (207 \times \text{Oil Rate} + 131,211), \quad (1)$ 

where CO<sub>2</sub> Rate is the peak CO<sub>2</sub> recycle rate (MMscfd), Pressure is the inlet gas pressure (psig), and Oil Rate is the peak oil production (barrels per day [bpd]).

Figure 4 shows a correlation graph for the estimated FCI cost and the modeled FCI cost for the data in the two studies. If the model correlated perfectly with the estimated costs, the data points would fall on the 45° line. As shown in the graph, the model correlates within 5% for the large-scale EOR cases and within approximately 28% for the small-scale cases. The model is valid for only the water-to-gas, oil-to-gas, and  $CO_2$  compression ratios used in the two studies. Extrapolation to conditions that vary significantly from these could produce erroneous results.

### **Effect of Facility Inlet Pressure**

Table 6 shows the effect of the facility inlet pressure on the high-pressure compressor purchased equipment costs. On the basis of cost estimates for the large-scale EOR cases, higher inlet pressures of 2,172 kPag (315 psig) result in approximately 25% lower purchased equipment costs for the compressors when compared with compressor costs when the  $CO_2$  facility pressure is 1,034 kPag (150 psig).

Compressor size and cost are a function of the suction actual volumetric flow rate, and the motor power requirement (and cost) is a function of both the pressure ratio and mass flow rate. For cases with a similar mass flow rate (Cases 1 and 2, Cases 3 and 4, and Cases 5 and 6), the lower facility inlet pressure results in a higher pressure ratio and more work being required to achieve the same discharge pressure of 6,895 kPag (1,000 psig). The lower facility inlet pressure cases (Cases 1, 3, and 5) also have a higher actual volumetric flow. Both of these parameters (higher pressure ratios and higher actual volumetric flow rates) make the compressors more expensive for the cases with a lower facility inlet pressure (Cases 1, 3, and 5) than the compressors for the cases with a higher facility inlet pressure (Cases 2, 4, and 6).

### MISCELLANEOUS COST ITEMS

The scope of Trimeric's work in this evaluation included estimates of the costs for potential environmental controls and the costs for flowlines to and from the EOR surface facilities.

### **Environmental Controls**

Environmental regulations have not been developed for EOR facilities in Illinois, so the information in this section is intended to provide some guidance about what costs could be encountered for providing air emissions control (of hydrocarbons, CO<sub>2</sub> gases, or both); however, this document is not a recommendation or prediction for what will be required. The EOR surface facilities evaluated have two potential sources of air (gas) emissions: the low-pressure suction scrubber and the oil storage tanks. Although crude oils from the ILB contain no hydrogen sulfide (H<sub>2</sub>S), additional environmental controls may be necessary if H<sub>a</sub>S is present in the produced fluids in other basins.

In this evaluation, the low-pressure gas flow rate is large enough to justify the installation of a low-pressure compressor in all cases. The flash gas generated in the low-pressure suction scrubber is compressed in a low-pressure compressor and combined with the inlet gas going to the high-pressure compressor train(s). Therefore, this potential emission source is eliminated. The costs for the lowpressure compressors are summarized in Table 7. These costs are also shown in the equipment cost tables for each case in Appendix B. The purchased equipment cost to recover the low-pressure flash gas constitutes approximately 9% to 13% of the total purchased equipment cost for each case.

### Table 5 Summary of the total fixed capital investment<sup>1</sup>

|   |        |            |            | Ca         | ise        |            |            |
|---|--------|------------|------------|------------|------------|------------|------------|
| Parameter   | Unit   | 1          | 2          | 3          | 4          | 5          | 6          |
| Actual gas flow   | acfm   | 3,142      | 1,466      | 6,283      | 2,931      | 12,570     | 5,862      |
| Produced gas flow   | MMscfd | 50         | 50         | 100        | 100        | 200        | 200        |
| Peak water capacity   | bpd    | 12,000     | 12,000     | 24,000     | 24,000     | 48,000     | 48,000     |
| Peak oil capacity   | bpd    | 3,000      | 3,000      | 6,000      | 6,000      | 12,000     | 12,000     |
| Inlet pressure  | psig   | 150        | 315        | 150        | 315        | 150        | 315        |
| Discharge pressure  | psig   | 1,000      | 1,000      | 1,000      | 1,000      | 1,000      | 1,000      |
| Installation phase(s)   |        | Single     | Single     | Multiple   | Multiple   | Multiple   | Multiple   |
| Equipment cost information  |        |            |            |            |            |            |            |
| Purchased equipment costs, January basis  | y 2015 |            |            |            |            |            |            |
| Separators, coolers, and chemical injection   | \$     | 1,081,000  | 1,016,000  | 1,991,000  | 1,889,000  | 3,817,000  | 3,640,000  |
| Oil tanks   | \$     | 219,000    | 219,000    | 438,000    | 438,000    | 876,000    | 876,000    |
| Compression   | \$     | 4,066,000  | 3,346,000  | 8,131,000  | 6,691,000  | 16,262,000 | 13,382,000 |
| Dehydration   | \$     | 1,612,000  | 1,612,000  | 2,444,000  | 2,444,000  | 4,888,000  | 4,888,000  |
| Building  | \$     | 480,000    | 480,000    | 839,000    | 839,000    | 1,371,000  | 1,371,000  |
| Total purchased equipment costs (PEC)   | \$     | 7,458,000  | 6,673,000  | 13,843,000 | 12,301,000 | 27,214,000 | 24,157,000 |
| Total installed equipment cost  | \$     | 11,538,400 | 10,373,800 | 21,342,500 | 19,058,400 | 42,113,900 | 37,588,300 |
| Capital cost information  |        |            |            |            |            |            |            |
| Factor for estimating the fixed<br>capital investment (FCI) for the<br>plant from the PEC |        | 3          | 3          | 3          | 3          | 3          | 3          |
| Total FCI   | \$     | 22,374,000 | 20,019,000 | 41,529,000 | 36,903,000 | 81,642,000 | 72,471,000 |

<sup>1</sup>acfm, actual cubic feet per minute; MMscfd, million standard cubic feet per day; bpd, barrels per day; psig, pounds per square inch gauge.



**Figure 3** Fixed capital investment as a function of the  $CO_2$  recycle rate and inlet pressure. MM, million; psig, pounds per square inch gauge.



Figure 4 Fixed capital investment model comparison with estimated costs. MM, million.

|  |               |         |         | Ca      | se      |         |         |
|--|---------------|---------|---------|---------|---------|---------|---------|
| Parameter  | Unit          | 1       | 2       | 3       | 4       | 5       | 6       |
| Facility inlet pressure  | psig          | 150     | 315     | 150     | 315     | 150     | 315     |
| Facility outlet pressure   | psig          | 1,000   | 1,000   | 1,000   | 1,000   | 1,000   | 1,000   |
| Pressure differential  | psi           | 850     | 685     | 850     | 685     | 850     | 685     |
| Pressure ratio   | dimensionless | 6.7     | 3.2     | 6.7     | 3.2     | 6.7     | 3.2     |
| Mass flow  | lb/h          | 239,420 | 235,733 | 478,765 | 471,305 | 957,834 | 942,610 |
| Standard volumetric flow   | MMscfd        | 50      | 50      | 100     | 100     | 200     | 200     |
| Actual volumetric flow   | acfm          | 3,142   | 1,466   | 6,283   | 2,931   | 12,570  | 5,862   |
| High-pressure CO <sub>2</sub> compressor power                         | hp            | 5,746   | 3,144   | 11,497  | 6,292   | 22,999  | 12,588  |
| Number of 25 MMscfd compressors  | —             | 2       | 2       | 2       | 2       | 2       | 2       |
| Number of 50 MMscfd compressors  | _             | 0       | 0       | 1       | 1       | 3       | 3       |
| Number of compression stages per<br>compressor                         | _             | 2       | 2       | 2       | 2       | 2       | 2       |
| High-pressure CO <sub>2</sub> compressor and air cooler purchased cost | \$MM          | 4.05    | 3.09    | 7.94    | 6.02    | 15.72   | 11.97   |

Table 6 Effect of facility inlet pressure on the high-pressure compressor purchased cost<sup>1</sup>

<sup>1</sup>psig, pounds per square inch gauge; psi, pounds per square inch; MMscfd, million standard cubic feet per day; acfm, actual cubic feet per minute; hp, horsepower; MM, million.

Table 7 Low-pressure compressor purchased equipment cost estimates<sup>1</sup>

| Case | Vent gas flow<br>rate, Sm³/h<br>(MMscfd) | Vent gas<br>pressure,<br>kPag (psig) | Recovery compressor<br>discharge pressure, <sup>2</sup><br>kPag (psig) | Purchased equipment<br>cost,3 \$ |
|------|--|--------------------------------------|--|----------------------------------|
| 1    | 2,950 (2.5)                              | 165 (24)                             | 1,034 (150)  | 692,000                          |
| 2    | 2,950 (2.5)                              | 165 (24)                             | 2,172 (315)  | 816,000                          |
| 3    | 5,900 (5)                                | 165 (24)                             | 1,034 (150)  | 1,383,000                        |
| 4    | 5,900 (5)                                | 165 (24)                             | 2,172 (315)  | 1,632,000                        |
| 5    | 11,800 (10)                              | 165 (24)                             | 1,034 (150)  | 2,766,000                        |
| 6    | 11,800 (10)                              | 165 (24)                             | 2,172 (315)  | 3,265,000                        |

<sup>1</sup>Sm<sup>3</sup>/h, standard cubic meters per hour; MMscfd, million standard cubic feet per day; kPag, kilopascal gauge; psig, pounds per square inch gauge.

<sup>2</sup>Assumes that the recovered vapor will be returned to the high-pressure compressor suction.

<sup>3</sup>All costs obtained using Aspen In-Plant Cost Estimator software.

The working losses1 from the oil storage tanks could increase if the oil production rate increases with the change from waterflood to CO, flood. The characteristics of the vapors vented as working losses would depend on the composition of the produced oil, so it is difficult to specify which emission controls might be required for the storage tank vents. A flare (with or without an inlet air blower) is a typical vapor emissions control device for oil storage tank vents, but proper flare design is critical for smoke-free operation with low-pressure oil storage tank vents. Alternatively, a compressor called a vapor recovery unit, similar to the low-pressure compressor, could be used to send the recovered storage tank vapors to the suction of the low-pressure compressor. which ultimately goes to the suction of the high-pressure compressor, and then to reinjection.

### **Flowline Piping**

The sizes for flowlines to carry the produced fluids to the EOR surface facility can be estimated by assuming a typical design velocity for two-phase flow of 9.1 m/s (30 ft/s) or less. Estimated material costs for selected piping diameters that may be applicable for the large-scale EOR facility cases are shown in Table 8. The actual piping diameter in a given application would depend on the total volume of fluid transported in that flowline. Separate flowline sizing calculations would also be required for flowlines to transport CO<sub>a</sub> from the central facility back to the injection wells. The estimated piping capital costs (NETL 2013) are shown, assuming carbon steel as the construction material for the piping. Stainless steel piping

costs could range from approximately 1.5 to 4 times that of the carbon steel estimates. Carbon steel and stainless steel could be specified for flowlines going to and from the central facility. Carbon steel would likely be more common, given the anticipated difference in capital cost. Other options in these types of applications can include fiberglass and carbon steel with internal corrosion-resistant coatings. A full analysis of the installed cost for the flowlines was not within the scope of Trimeric's work for this evaluation because such an analysis requires details or assumptions regarding the number of wells, distances between the wells, and intermediate satellite test facilities where production from multiple wells is measured and then aggregated and transported to the central facility, as well as site-specific decisions regarding construction materials for the flowlines.

### CONCLUSIONS

The primary functions of a  $CO_2$  EOR central facility or  $CO_2$  recycle facility are to (1) separate produced gas (primarily  $CO_2$  with some hydrocarbons) from the produced liquids (oil and water), (2) compress the produced gas for reinjection into the  $CO_2$  EOR flood, and (3) separate the produced oil and water and provide short-term storage of these products. Major central facility components include separators, compressors, and storage tanks.

This report provides a correlation that can be used to estimate the FCI for central facilities as a function of  $CO_2$  recycle rates ranging from 1,180 Sm<sup>3</sup>/h (1 MMscfd) to 236,000 Sm<sup>3</sup>/h (200 MMscfd) for suction pressures of 1,034 kPag (150 psig) or 2,172 kPag (315 psig) and a discharge pressure of 6,895 kPag (1,000 psig). The capital costs used as inputs to the correlation for the small recycle facilities (1,180 to 24,780 Sm<sup>3</sup>/h [1 to 21 MMscfd]) were taken from an evaluation Trimeric performed for the ISGS in 2013 for smaller EOR central facilities. Costs for facilities with recycle rates ranging from 59,000 Sm3/h (50 MMscfd) to 236,000 Sm<sup>3</sup>/h (200 MMscfd) were developed in the current report. Together, these conditions represent ranges that might be expected for any early-phase CO<sub>2</sub> EOR floods in the ILB. Estimates of major operating costs for the larger EOR CO, recycle facilities are also provided.

The FCI for this type of facility is typically dominated by compressor costs. Smaller compressors are often installed in parallel at the beginning of an EOR flood operation rather than installing one larger compressor. This setup provides more operational flexibility as the CO<sub>a</sub> rate returning from the production wells begins to increase. Larger compressors are often installed in later years in a phased approach as the produced gas rate from the field continues to increase. This method reduces major capital expenditures for several years and reduces the risk of installing equipment or equipment capacity at the beginning of the flood that might not be needed if actual operations differ from original projections.

Compressor costs are a function of the suction pressure, discharge pressure, gas composition, and mass flow rate of the gas. These factors can have varying degrees of influence on a case-by-case

<sup>1</sup>"Working losses" from oil storage tanks are the vapors that are pushed out the vent when the liquid level rises during production.

 
 Table 8 Unit purchased material capital costs for flowline piping<sup>1</sup>

| Pipe diameter,<br>mm (in.) | Carbon steel pipe cost,<br>\$/mi |
|----------------------------|----------------------------------|
| 50.8 (2)                   | 115,000                          |
| 101.6 (4)                  | 126,000                          |
| 152.4 (8)                  | 162,000                          |
| 304.8 (12)                 | 220,000                          |
| 406.4 (16)                 | 298,000                          |

<sup>1</sup>Piping material costs can fluctuate significantly. It is necessary to verify current pricing at the beginning of each project.

basis, but the suction pressure (which influences the actual volumetric flow rate of the gas to be compressed) is often an important factor in determining compressor costs.

### ACKNOWLEDGMENTS

The MGSC is funded by the U.S. Department of Energy through the National Energy Technology Laboratory (NETL) via the Regional Carbon Sequestration Partnership Program (contract number DE-FC26-05NT42588) and by a cost-share agreement with the Illinois Department of Commerce and Economic Opportunity, Office of Coal Development through the Illinois Clean Coal Institute.

### REFERENCES

Chemical Engineering Magazine, 2015, Chemical engineering plant cost index: Chemical Engineering Magazine, April, p. 80.

- Monnery, W.D., and W.Y. Svrcek, 1994, Successfully specify three-phase separators: Chemical Engineering Process, v. 90, no. 9, 29–40.
- Monson, C.C., 2012, Capital and operating expenses specific to Illinois Basin oilfield, Task 3 *in* CCUS Performance Curve Study. Champaign: Illinois State Geological Survey.
- Morris, R.C., and J.A. Williams, 2001, Project evaluation: Operating cost estimating and financial analysis: New York, American Institute of Chemical Engineers, Public Course CH140.
- Myers, D.B., C.M. Beitler, R.W. McKaskle, and S.M. Frailey, 2017, A universal methodology to develop, test, and calibrate a carbon dioxide enhanced

oil recovery and storage capacity estimate: Champaign, Illinois State Geological Survey, Circular 591, 46 p.

- National Energy Technology Laboratory (NETL), 2013, Quality guidelines for energy system studies: Carbon dioxide transport and storage costs in NETL studies: Washington, DC, U.S. Department of Energy, Final Report for DOE/ NETL-2013/1614.
- Peters, M.S., K. Timmerhaus, and R.E. West, 2003, Plant design and economics for chemical engineers, 5th ed.: Columbus, Ohio, McGraw-Hill Education, 1008 p.
- Trimeric Corporation, 2016, Task 1.12.4.1 deliverable: Document design of general  $CO_2$  EOR facility for ILB: Champaign, Illinois State Geological Survey, Technical Report for DOE Contract DE-FC26-05NT42588.



## **Process Flow Diagrams for Cases 1-6**



Figure A1 Process flow diagram for Case 1.



Figure A2 Process flow diagram for Case 2.





## Figure A4 Process flow diagram for Case 4.





### **APPENDIX B**

# Equipment List and Purchased and Installed Costs for Cases 1–6

Table B1 Case 1-Major equipment list, and purchased and installed costs<sup>1</sup>

|      | Jan 2015<br>total installed              | cost, \$     | 243,500  | 447,300                                   | 644,600                                   | 73,300                      | 74,100                      | 190,100  | 108,100  | 14,800  | 21,400                           | 411,500   | 5,027,100   | 1,030,500   | 2,772,600   | 479,500               | 11,538,400                                    | ID, inside   |
|------|--|--------------|--|---|---|-----------------------------|-----------------------------|--|--|---|----------------------------------|---|---|---|---|-----------------------|---|--|
|      | Installation                             | factor       | 0.88   | 0.61                                      | 0.61                                      | 0.61                        | 0.61                        | 0.88   | 0.88   | 0.30  | 0.88                             | 0.88  | 0.49  | 0.49  | 0.72  | 0.00                  | 18 m <sup>3</sup> /d of water (               | P, low pressure;   |
|      | Jan 2015 total<br>purchased<br>equipment | cost, \$     | 129,500  | 277,800                                   | 400,400                                   | 45,500                      | 46,000                      | 101,100  | 57,500   | 11,400  | 11,400                           | 218,900   | 3,373,900   | 691,600   | 1,612,000   | 479,500               | 7,456,500                                     | per uay]), anu 1,90<br>P, high pressure; L                                   |
|      | Jan<br>2015<br>plant                     | index        | 573.1  | 573.1                                     | 573.1                                     | 573.1                       | 573.1                       | 573.1  | 573.1  | 573.1   | 573.1                            | 573.1   | 573.1   | 573.1   | 573.1   | 573.1                 | harrels of oil                                | cility outlet. H   |
|      | Plant index<br>equipment                 | basis        | 572.8  | 564.8                                     | 564.8                                     | 564.8                       | 564.8                       | 572.8  | 572.8  | 572.8   | 572.8                            | 572.8   | 579.7   | 572.8   | 573.1   | 572.8                 | f oil (3 000 hond                             | ag (1,000 psig) fa   |
|      | No.<br>of                                | units        | -  | N   | N   | <del>.  </del>              | -                           | -  | -  | N   | <del></del>                      | <del></del>   | N   | -   | <del></del>   | -                     | 476 m³/d of                                   | 470 III7U 0<br>1; 6,895 kPa  |
| Unit | equipment<br>cost before<br>indexing to  | Jan 2015, \$ | 129,400  | 136,900                                   | 197,300                                   | 44,800                      | 45,300                      | 101,000  | 57,500   | 5,700   | 11,400                           | 218,800   | 1,706,400   | 691,200   | 1,612,000   | 479,200               | t per dav1) of CO                             | auge]) facility inle   |
|      | Design<br>temperature                    | rating, °F   | 200  | 350                                       | 350                                       | 350                         | 350                         | 200  | 200  | 150   | 150                              | 150   | NA  | NA  | 150   | NA                    | standard cubic feet                           | stantiario cubic teel<br>s per square inch (                                 |
|      | Design<br>pressure                       | rating, psig | 250  | 500                                       | 1,200                                     | 250                         | 250                         | 50   | 50   | 50  | Hydrostatic<br>+ 2.5 psig        | Hydrostatic<br>+ 2.5 psig   | NA  | NA  | 1,100   | NA                    | MMscfd [million s                             | e; 150 psig [pound   |
|      |  | Description  | Horizontal 2-phase separator vessel, 7.5 ft ID × 24 ft S/S length, coated carbon steel | SS air cooler, 3.14 MMBtu/h               | SS air cooler, 5.75 MMBtu/h               | SS air cooler, 0.49 MMBtu/h | SS air cooler, 0.50 MMBtu/h | Horizontal 3-phase separator<br>vessel, 11 ft × 17 ft S/S length,<br>coated carbon steel | Horizontal 3-phase separator vessel, 6 ft $\times$ 18 ft S/S length, coated carbon steel | 0.039 gpm to give 90 ppm by volume in oil/water mixture | 790-gal tank for 14 d of storage | API storage tank 9,000 bbl capacity<br>each (for 3-d capacity at peak rate) | 25 MMscfd from 150 to 1,000 psig<br>(2,873 hp); 2-stage reciprocating<br>compressor; assumes mix of<br>coated carbon steel and SS<br>components | 2.5 MMscfd from 25 to 150 psig<br>(238 hp); 2-stage reciprocating<br>compressor; assumes mix of<br>coated carbon steel and SS<br>components | Treats 50 MMscfd after<br>compression at 1,000 psig | 3,844 ft <sup>2</sup> | 000 Sm³/h (standard cubic meters per hour: 50 | day]). Pressures: 1,034 kPag (kilopascal gauge to seam; SS, stainless steel. |
|      |  | Name         | Slug catcher   | HP air cooler–<br>1st stage, 25<br>MMscfd | HP air cooler–<br>2nd stage, 25<br>MMscfd | LP air cooler–<br>1st stage | LP air cooler–<br>2nd stage | Free water<br>knockout   | Demulsifier  | Chemical<br>injection pump                              | Chemical<br>injection tank       | Oil storage<br>tank   | HP<br>compressor  | LP<br>compressor  | Dehydration   | Building              | Total   | [barrels of water per-<br>diameter; S/S, seam                                |

|   |   | Docion                                  | Doctor                                    | Unit equipment                                    |   |  | Jan                             | Jan 2015 total                                    |  | Jan 2015                   |
|---|---|---|---|---|---|--|---------------------------------|---|--|----------------------------|
| Name  | Description   | pressure<br>rating, psig                | temperature<br>rating, °F                 | indexing to Jan<br>2015, \$                       | of<br>units                               | equipment<br>basis                       | plant<br>plant<br>index         | equipment<br>cost, \$                             | Installation<br>factor                   | installed<br>cost, \$      |
| Slug catcher  | Horizontal 2-phase separator<br>vessel, 7.5 ft ID × 24 ft S/S<br>length, coated carbon steel  | 450                                     | 200                                       | 176,100   | -   | 572.8                                    | 573.1                           | 176,200   | 0.88                                     | 331,300                    |
| HP air cooler–<br>1st stage, 25<br>MMscfd   | SS air cooler, 2.82 MMBtu/h   | 750                                     | 350                                       | 128,300   | N   | 564.8                                    | 573.1                           | 260,400   | 0.61                                     | 419,200                    |
| HP air cooler–<br>2nd stage, 25<br>MMscfd   | SS air cooler, 3.66 MMBtu/h   | 1,200                                   | 350                                       | 150,200   | N   | 564.8                                    | 573.1                           | 304,800   | 0.61                                     | 490,700                    |
| LP air cooler-<br>1st stage   | SS air cooler, 0.49 MMBtu/h   | 250                                     | 350                                       | 45,000  | -   | 564.8                                    | 573.1                           | 45,700  | 0.61                                     | 73,600                     |
| LP air cooler–<br>2nd stage   | SS air cooler, 0.52 MMBtu/h   | 450                                     | 350                                       | 46,500  | ÷   | 564.8                                    | 573.1                           | 47,200  | 0.61                                     | 76,000                     |
| Free water<br>knockout  | Horizontal 3-phase separator vessel, 11 ft × 17 ft S/S length, coated carbon steel  | 50                                      | 200                                       | 101,000   | -   | 572.8                                    | 573.1                           | 101,100   | 0.88                                     | 190,100                    |
| Demulsifier   | Horizontal 3-phase separator<br>vessel, 6 ft × 18 ft S/S length,<br>coated carbon steel   | 50                                      | 200                                       | 57,500  | -   | 572.8                                    | 573.1                           | 57,500  | 0.88                                     | 108, 100                   |
| Chemical<br>injection pump  | 0.039 gpm to give 90 ppm by volume in oil   | 50                                      | 150                                       | 5,700   | N   | 572.8                                    | 573.1                           | 11,400  | 0.30                                     | 14,800                     |
| Chemical<br>injection tank  | 790-gal tank for 14 d of storage  | Hydrostatic<br>+ 2.5 psig               | 150                                       | 11,400  | -   | 572.8                                    | 573.1                           | 11,400  | 0.88                                     | 21,400                     |
| Oil storage<br>tank   | API storage tank 9,000 bbl<br>capacity each (for 3-d capacity<br>at peak rate)  | Hydrostatic<br>+ 2.5 psig               | 150                                       | 218,800   | -   | 572.8                                    | 573.1                           | 218,900   | 0.88                                     | 411,500                    |
| HP compressor   | 25 MMscfd from 315 to 1,000<br>psig (1,572 hp); 2-stage<br>reciprocating compressor;<br>assumes mix of coated carbon<br>steel and SS components | AN                                      | NA  | 1,279,300   | N   | 579.7                                    | 573.1                           | 2,529,500   | 0.49                                     | 3,769,000                  |
| LP compressor   | 2.5 MMscfd from 25 to 315 psig<br>(418 hp); 2-stage reciprocating<br>compressor; assumes mix of<br>coated carbon steel and SS<br>components     | AN                                      | NA  | 815,700   | -   | 572.8                                    | 573.1                           | 816, 100  | 0.49                                     | 1,216,000                  |
| Dehydration   | Treats 50 MMscfd after<br>compression at 1,000 psig   | 1,100                                   | 150                                       | 1,612,000   | -   | 573.1                                    | 573.1                           | 1,612,000   | 0.72                                     | 2,772,600                  |
| Building  | 3,844 ft²   | NA                                      | NA  | 479,200   | ÷   | 572.8                                    | 573.1                           | 479,500   | 0.00                                     | 479,500                    |
| Total   |   |   |   |   |   | 572.8                                    | 573.1                           | 6,671,700   |  | 10,373,800                 |
| <sup>1</sup> Production rates: 59<br>bwpd [barrels of wat<br>inside diameter; S/S | 0,000 Sm <sup>3</sup> /h (standard cubic meters per f<br>ter per day]). Pressures: 2, 172 kPag (kilo<br>), seam to seam; SS, stainless steel.   | hour; 50.0 MMscfd<br>ppascal gauge; 315 | [million standard c<br>psig [pounds per a | :ubic feet per day]) of<br>square inch gauge]) fa | CO <sub>2</sub> , 476 n<br>acility inlet; | n³/d of oil (3,000 b<br>6,895 kPag (1,00 | oopd [barrels<br>0 psig) facili | t of oil per day]), and<br>ty outlet. HP, high pr | l 1,908 m³/d of wa<br>essure; LP, low pr | ter (12,000<br>essure; ID, |

Table B2 Case 2-Major equipment list, and purchased and installed costs<sup>1</sup>

|                   | Jan 2015          | total<br>installed     | cost, \$     | 486,700   | 447,300                               | 644,600                               | 338,700                               | 488,500                               | 146,300                     | 148,000                     | 379,900  | 216,400  | 22,200                                    | 42,900                           | 823, 100   | 5,027,300   | 5,027,100   | 2,060,800   | 4,203,700   | 839,000<br>21,342,500 |
|-------------------|-------------------|------------------------|--------------|---|---------------------------------------|---------------------------------------|---------------------------------------|---------------------------------------|-----------------------------|-----------------------------|--|--|---|----------------------------------|--|---|---|---|---|-----------------------|
|                   |                   | Installation           | factor       | 0.88  | 0.61                                  | 0.61                                  | 0.61                                  | 0.61                                  | 0.61                        | 0.61                        | 0.88   | 0.88   | 0.30                                      | 0.88                             | 0.88   | 0.49  | 0.49  | 0.49  | 0.72  | 0.00                  |
|                   | Jan 2015<br>total | purchased<br>equipment | cost, \$     | 258,900   | 277,800                               | 400,400                               | 210,400                               | 303,400                               | 90,900                      | 91,900                      | 202,100  | 115,100  | 17,100                                    | 22,800                           | 437,800  | 3,374,000   | 3,373,900   | 1,383,100   | 2,444,000   | 839,000<br>13,842,600 |
|                   | Jan               | 2015<br>plant          | index        | 573.1   | 573.1                                 | 573.1                                 | 573.1                                 | 573.1                                 | 573.1                       | 573.1                       | 573.1  | 573.1  | 573.1                                     | 573.1                            | 573.1  | 573.1   | 573.1   | 573.1   | 573.1   | 573.1                 |
|                   | Plant             | index<br>equipment     | basis        | 572.8   | 564.8                                 | 564.8                                 | 564.8                                 | 564.8                                 | 564.8                       | 564.8                       | 572.8  | 572.8  | 572.8                                     | 572.8                            | 572.8  | 579.7   | 579.7   | 572.8   | 573.1   | 572.8                 |
|                   |                   | of No.                 | units        | N   | N                                     | N                                     | -                                     | -                                     | N                           | 2                           | N  | N  | с   | N                                | N  | -   | N   | N   | -   | -                     |
| Unit<br>equipment | cost<br>before    | indexing<br>to Jan     | 2015, \$     | 129,400   | 136,900                               | 197,300                               | 207,400                               | 299,000                               | 44,800                      | 45,300                      | 101,000  | 57,500   | 5,700                                     | 11,400                           | 218,800  | 3,412,900   | 1,706,400   | 691,200   | 2,444,000   | 838,600               |
|                   |                   | Design<br>temnerature  | rating, °F   | 200   | 350                                   | 350                                   | 350                                   | 350                                   | 350                         | 350                         | 200  | 200  | 150                                       | 150                              | 150  | NA  | NA  | NA  | 150   | NA                    |
|                   |                   | Design                 | rating, psig | 250   | 500                                   | 1,200                                 | 500                                   | 1,200                                 | 250                         | 250                         | 50   | 50   | 50  | Hydrostatic<br>+ 2.5 psig        | Hydrostatic<br>+ 2.5 psig  | NA  | NA  | NA  | 1,100   | NA                    |
|                   |                   |                        | Description  | Horizontal 2-phase separator vessel, 7.5 ft ID $\times$ 24 ft S/S length, coated carbon steel | SS air cooler, 3.14 MMBtu/h           | SS air cooler, 5.75 MMBtu/h           | SS air cooler, 6.27 MMBtu/h           | SS air cooler, 11.5 MMBtu/h           | SS air cooler, 0.49 MMBtu/h | SS air cooler, 0.50 MMBtu/h | Horizontal 3-phase separator vessel, 11 ft × 17 ft S/S length, coated carbon steel | Horizontal 3-phase separator vessel, 6 ft $\times$ 18 ft S/S length, coated carbon steel | 0.039 gpm to give 90 ppm by volume in oil | 790-gal tank for 14 d of storage | API storage tank 9,000 bbl capacity each (for 3-d capacity at peak rate) | 50 MMscfd from 150 to 1,000 psig (5,751 hp); 2-stage reciprocating compressor; assumes mix of coated carbon steel and SS components | 25 MMscfd from 150 to 1,000 psig (2,873 hp); 2-stage reciprocating compressor; assumes mix of coated carbon steel and SS components | <ol> <li>2.5 MMscfd from 25 to 150 psig (238<br/>hp); 2-stage reciprocating compressor;<br/>assumes mix of coated carbon steel and<br/>SS components</li> </ol> | Treats 100 MMscfd after compression at 1,000 psig | 6,724 ft²             |
|                   |                   |                        | Name         | Slug catcher  | HP air cooler–1st<br>stage, 25 MMscfd | HP air cooler–2nd<br>stage, 25 MMscfd | HP air cooler–1st<br>stage, 50 MMscfd | HP air cooler–2nd<br>stage, 50 MMscfd | LP air cooler–1st<br>stage  | LP air cooler–2nd<br>stage  | Free water knockout  | Demulsifier  | Chemical injection<br>pump                | Chemical injection<br>tank       | Oil storage tank   | HP compressor, 50<br>MNscfd   | HP compressor, 25<br>MNscfd   | LP compressor   | Dehydration                                       | Building<br>Total     |

<sup>1</sup>Production rates: 118,000 Sm<sup>3</sup>/h (standard cubic meters per hour; 100 MMScfd [million standard cubic feet per day]) of CO<sub>2</sub>, 953 m<sup>3</sup>/d of oil (6,000 bopd [barrels of oil per day]), and 3815 m<sup>3</sup>/d of water (24,000 bwpd [barrels of water per day]). Pressures: 1,034 kPag (kilopascal gauge; 150 psig [pounds per square inch gauge]) facility inlet; 6,895 kPag (1,000 psig) facility outlet. HP, high pressure; LP, low pressure; ID, inside diameter; S/S, seam to seam; SS, stainless steel.

<sup>1</sup>Production rates: 118,000 Sm<sup>3</sup>/h (standard cubic meters per hour; 100 MMscfd [million standard cubic feet per day]) of CO<sub>2</sub>, 953 m<sup>3</sup>/d of oil (6,000 bopd [barrels of oil per day]), and 3,815 m<sup>3</sup>/d of water (24,000 bypd [barrels of water per day]). Pressures: 2,172 kPag (kilopascal gauge; 315 psig [pounds per square inch gauge]) facility inlet; 6,895 kPag (1,000 psig) facility outlet. HP, high pressure; LP, low pressure; ID, inside diameter; S/S, seam to seam; SS, stainless steel.

Table B4 Case 4-Major equipment list, and purchased and installed costs<sup>1</sup>

|                                       |   | Design                    | Design<br>temperature | Unit<br>equipment<br>cost<br>before<br>indexing<br>to Jan | of No.                   | Plant<br>index<br>equipment | Jan<br>2015<br>plant | Jan 2015<br>total<br>purchased<br>equipment | Installation                  | Jan 2015<br>total<br>installed |
|---------------------------------------|---|---------------------------|-----------------------|---|--------------------------|-----------------------------|----------------------|---|-------------------------------|--------------------------------|
| Name                                  | Description   | rating, psig              | rating, °F            | 2015, \$  | units                    | basis                       | index                | cost, \$                                    | factor                        | cost, \$                       |
| Slug catcher                          | Horizontal 2-phase separator vessel, 7.5<br>ft ID × 24 ft S/S length, coated carbon<br>steel  | 250                       | 200                   | 129,400   | 4                        | 572.8                       | 573.1                | 517,900                                     | 0.88                          | 973,700                        |
| HP air cooler-1st<br>stage, 25 MMscfd | SS air cooler, 3.14 MMBtu/h   | 500                       | 350                   | 136,900   | N                        | 564.8                       | 573.1                | 277,800                                     | 0.61                          | 447,300                        |
| HP air cooler-2nd<br>stage, 25 MMscfd | SS air cooler, 5.75 MMBtu/h   | 1,200                     | 350                   | 197,300   | N                        | 564.8                       | 573.1                | 400,400                                     | 0.61                          | 644,600                        |
| HP air cooler-1st<br>stage, 50 MMscfd | SS air cooler, 6.27 MMBtu/h   | 500                       | 350                   | 207,400   | с                        | 564.8                       | 573.1                | 631,300                                     | 0.61                          | 1,016,400                      |
| HP air cooler-2nd<br>stage, 50 MMscfd | SS air cooler, 11.5 MMBtu/h   | 1,200                     | 350                   | 299,000   | ю                        | 564.8                       | 573.1                | 910,200                                     | 0.61                          | 1,465,400                      |
| LP air cooler–1st<br>stage            | SS air cooler, 0.49 MMBtu/h   | 250                       | 350                   | 44,800  | 4                        | 564.8                       | 573.1                | 181,800                                     | 0.61                          | 292,700                        |
| LP air cooler–2nd<br>stage            | SS air cooler, 0.50 MMBtu/h   | 250                       | 350                   | 45,300  | 4                        | 564.8                       | 573.1                | 183,900                                     | 0.61                          | 296, 100                       |
| Free water knockout                   | Horizontal 3-phase separator vessel, 11 ft $\times$ 17 ft S/S length, coated carbon steel   | 50                        | 200                   | 101,000   | 4                        | 572.8                       | 573.1                | 404,200                                     | 0.88                          | 759,900                        |
| Demulsifier                           | Horizontal 3-phase separator vessel, 6 ft × 18 ft S/S length, coated carbon steel   | 50                        | 200                   | 57,500  | 4                        | 572.8                       | 573.1                | 230,100                                     | 0.88                          | 432,600                        |
| Chemical injection<br>pump            | 0.039 gpm to give 90 ppm by volume in oil   | 50                        | 150                   | 5,700   | 9                        | 572.8                       | 573.1                | 34,200                                      | 0.30                          | 44,500                         |
| Chemical injection<br>tank            | 790-gal tank for 14 d of storage  | Hydrostatic<br>+ 2.5 psig | 150                   | 11,400  | 4                        | 572.8                       | 573.1                | 45,600                                      | 0.88                          | 85,700                         |
| Oil storage tank                      | API storage tank 9,000 bbl capacity each (for 3-d capacity at peak rate)  | Hydrostatic<br>+ 2.5 psig | 150                   | 218,800   | 4                        | 572.8                       | 573.1                | 875,700                                     | 0.88                          | 1,646,300                      |
| HP compressor, 50<br>MMscfd           | 50 MMscfd from 150 to 1,000 psig (5,751 hp); 2-stage reciprocating compressor; assumes mix of coated carbon steel and SS components | AN                        | NA                    | 3,412,900   | ო                        | 579.7                       | 573.1                | 10,122,100                                  | 0.49                          | 15,081,900                     |
| HP compressor, 25<br>MMscfd           | 25 MMscfd from 150 to 1,000 psig (2,873 hp); 2-stage reciprocating compressor; assumes mix of coated carbon steel and SS components | AN                        | NA                    | 1,706,400   | 2                        | 579.7                       | 573.1                | 3,373,900                                   | 0.49                          | 5,027,100                      |
| LP compressor                         | 2.5 MMscfd from 25 to 150 psig (238 hp); 2-stage reciprocating compressor; assumes mix of coated carbon steel and SS components     | AN                        | AN                    | 691,200   | 4                        | 572.8                       | 573.1                | 2, 766, 200                                 | 0.49                          | 4,121,600                      |
| Dehydration                           | Treats 100 MMscfd after compression at 1,000 psig   | 1,100                     | 150                   | 2,444,000   | N                        | 573.1                       | 573.1                | 4,888,000                                   | 0.72                          | 8,407,400                      |
| Building                              | 11,025 ft <sup>2</sup>  | NA                        | NA                    | 1,370,000   | -                        | 572.8                       | 573.1                | 1,370,700                                   | 00.00                         | 1,370,700                      |
| Total                                 |   |                           |                       |   |                          |                             |                      | 27,214,000                                  |                               | 42, 113,900                    |
| Production rates: 236.000 S           | m <sup>3</sup> /h (standard cubic meters per hour; 200 MMscfd [m  | nillion standard cu       | bic feet per dav])    | of CO 1.906 m   | <sup>3</sup> /d of oil ( | 12.000 bood [ba             | rrels of oil         | ner davl) and 7                             | 630 m <sup>3</sup> /d of wate | r (48 000 hwnd                 |

[barrels of water per day]). Pressures: 1,034 kPag (kilopascal gauge; 150 psig [pounds per square inch gauge]) facility inlet, 6,895 kPag (1,000 psig) facility outlet. HP, high pressure; LP, low pressure; ID, inside diameter; S/S, seam to seam; SS, stainless steel.

| Design |
|--------|
| sure   |
|        |
|        |
|        |
|        |
|        |
|        |
|        |
|        |
|        |
|        |
| 0 5    |
| O<br>D |
|        |
|        |
|        |
|        |
|        |
|        |

, mgn pr 2 (filed) ag (1,00 ~ gaugel 5 5 nd] fiisd i gauge, ž ay (KI parrels of water per day J). Pressures: 2,1 S/S, seam to seam; SS, stainless steel.

Table B6 Case 6-Major equipment list, and purchased and installed costs<sup>1</sup>